

QUALITY. VALUE. ECONOMIC GROWTH.

WWW.MIAMIDADE.GOV/WATER




MIAMI-DADE
COUNTY

Sheet Number: 8.5

Product Specifications

Miami-Dade Water & Sewer Department
Address: 3071 SW 38th Ave, Miami, FL 33146
Phone: (305) 665-7477

Water Services – Meter Valves



Minimum Standards

- AWWA C700,C800
- MDWASD Specifications: Section 15065
- 300 PSI Pressure Rating

Other Requirements

- ANSI/NSF Standard 61
- No Lead – All brass components shall be marked “NL”
- Bronze Construction per ASTM B584

Applications

- Water

PRE-APPROVED MANUFACTURER

- | | |
|------------------|--------------------|
| 1) A.Y. McDonald | 3) Mueller |
| 2) Ford | 4) Cambridge Brass |

Issue Date:

4/4/2016

Revised Date:

5/09/2018

APPROVED PRODUCTS / MODELS

SIZE	MANUFACTURER	MODEL	SUBMITTED
1" - 1¼" x 1" x 1"	A.Y. McDonald	76100M-22 Ball Style Meter Stop	<input type="checkbox"/>
5/8" - 1½"	A.Y. McDonald	74602B-22 Ball Style Meter Stop	<input type="checkbox"/>
	A.Y. McDonald	74606B-44 (2" Angle Ball Valve PVC Pack Joint x FNPT)	<input type="checkbox"/>
¾" - 1¼"	Ford	B13-xxxW-NL Ball Meter Valve	<input type="checkbox"/>
¾" - 1"	Ford	BA43-3xxW-G-NL Angle Ball Meter Valve	<input type="checkbox"/>
1"	Ford	BA43-444W-NL Angle Ball Meter Valve	<input type="checkbox"/>
1½" - 2½"	Ford	BF13-xxxW-NL Ball Flange Meter Valve	<input type="checkbox"/>
1½" - 2½"	Ford	BF43-xxxW-NL Ball Flange Meter Valve	<input type="checkbox"/>
¾"	Mueller	300 Ball Angle Meter Valve P-24265N	<input type="checkbox"/>
1"	Mueller	300 Ball Angle Meter Valve B-24258N	<input type="checkbox"/>
¾"-1"	Cambridge	210NL-Series	<input type="checkbox"/>
1-1/2" - 2-1/2"	Cambridge	212NL-BXMX (1-1/2"&2")	<input type="checkbox"/>

SIZE FURNISHED:

Inlet Size:

Outlet Size: -

COMMENTS:

Approved by: MDWASD Departmental Standards, Specifications, and Product Committee

Revision History:
5-09-2018 – Added Cambridge Brass