



Sheet Number: 8.7

Product Specifications

Miami-Dade Water & Sewer Department
Address: 3071 SW 38th Ave, Miami, FL 33146
Phone: (305) 665-7477
Email: WASD-STANDARDS@miamidade.gov

Water Services – Tubing



Minimum Standards

- AWWA C901 (HDPE)
- ASTM D3350 (HDPE)
- ASTM B88 (Copper)
- MDWASD Specifications: Section 33 14 00 (15060), 33 14 17 (UC-075)

Other Requirements

- NSF/ANSI 61 & 14 for potable water applications
- Color blue for water application
- For Copper/Bronze Tubing: Type K, annealed and coiled
- HDPE Tubing 2": IPS O.D. SODR 9, 250 PSI pressure rating
- HDPE Tubing 1": CTS O.D. SODR 9, 250 PSI pressure rating

Applications

- Tubing for water service lines

PRE-APPROVED MANUFACTURER

- 1) Cerro Flow Products, Inc.
- 2) Endot Industries, Inc.

Issue Date:

4-4-2016

Revised Date:

8/15/2022

APPROVED PRODUCTS / MODELS

PIPE SIZE	MANUFACTURER	MODEL	SUBMITTED
1" - 2"	Cerro Flow Products, Inc.	Cerro Tube	<input type="checkbox"/>
2"	Endot Industries, Inc.	HDPE EndoPure PE-4710	<input type="checkbox"/>
2"	Endot Industries, Inc.	Endopoly/Endopure	<input type="checkbox"/>
3/4" - 2"	Endot Industries, Inc.	Endotrace	<input type="checkbox"/>
			<input type="checkbox"/>

SIZE FURNISHED:

- | | |
|---------------------------------|---------------------------------|
| <input type="checkbox"/> 3/4" | <input type="checkbox"/> 1 1/2" |
| <input type="checkbox"/> 1" | <input type="checkbox"/> 2" |
| <input type="checkbox"/> 1 1/4" | <input type="checkbox"/> Other |

COMMENTS: _____

Approved by: MDWASD DEPARTMENTAL STANDARDS, SPECIFICATIONS AND PRODUCTS COMMITTEE

Revision History:

08/15/2022 – Removed Advanced Drainage Systems, ADS Poly Flex;