

QUALITY. VALUE. ECONOMIC GROWTH.

WWW.MIAMIDADE.GOV/WATER



MIAMI-DADE COUNTY

Sheet Number: 9.0

Product Specifications

Miami-Dade Water & Sewer Department
Address: 3071 SW 38th Ave, Miami, FL 33146
Phone: (305) 665-7477

Fire Hydrants



Minimum Standards

- AWWA C502
MDWASD Specification: Section 15060, 15330

Other Requirements

- Color: Chrome Yellow

Applications

- Water

PRE-APPROVED MANUFACTURER

- 1) American (American Flow Control)
2) Clow
3) Kennedy
4) Mueller

Issue Date: 4/4/2016

Revised Date:

APPROVED PRODUCTS / MODELS

Table with 4 columns: SIZE, MANUFACTURER, MODEL, SUBMITTED. Rows include American (American Flow Control), Clow, Kennedy, and Mueller models.

COMMENTS:

Approved by: James B. Ferguson, PE

Title: Chief, Engineering and Design Division